



कार्यालय सहायक यंत्री,
लोक स्वास्थ्य यांत्रिकी विभाग उपखण्ड लखनादौन (म.प्र.)



Email- aephelakhnadon@gmail.com

पत्र क्र.10...1 / लेखा/स.यं./लो.स्वा.यां./उपखण्ड / लखनादौन/2023 दिनांक ...19/1/2023
प्रति

संचालक
काव्या इंटरनेशनल स्कूल
सारसडोल, लखनादौन
जिला सिवनी (म.प्र.)

विषय :- पानी की लेब टेस्टिंग बावद्।

संदर्भ :- आपका पत्र क्र. 42 दिनांक 14.01.2023

उपरोक्त विषयान्तर्गत लेख है कि आपके द्वारा काव्या इंटरनेशनल स्कूल सारसडोल, लखनादौन का पीने का पानी का जल नमूना लेकर लोक स्वास्थ्य यांत्रिकी विभाग उपखण्डीय प्रयोगशाला लखनादौन में जल परीक्षण कर टेस्टिंग रिपोर्ट आपकी ओर प्रेषित है।


सहपत्र :- टेस्टिंग रिपोर्ट 01 नग


सहायक यंत्री
लोक स्वास्थ्य यांत्रिकी विभाग
उपखण्ड लखनादौन

WATER TESTING REPORT
P.H.E. SUB DIVISION LAKHNADON LABORATORY
BLOCK -Lakhnadon

s.no	Name of location	Received date	Testing date	Iron (1.0)mg/l	Nitrate(45)mg/l	Fluoride(1.0-1.5)mg/l	chloride (250-1000)mg/l	TDS(500-2000)mg/l	Alkalinity (200-600)mg/l	Sulphate(200-400)mg/l	Manganese(0.1-0.3)mg/l	pH(6.5-8.5)	Turbidity(1.0-5.0)NTU	Hardness(200-600)mg/l	Total coliform bacteria/E.coli(Shall not be detectable in any 100ml sample)
1	In Campus of kavya international school	16/01/2023	18/01/2023	0.67	6.3	0.215	116	412.5	126	127.0	0.00	7.3	1.1	152.0	0

Note 1. indicates parameters that are NABL accredited 2. This test result related to the sample tested above 3. the report shall not to be reproduced in full without approval of authority 4. **sample is safe for drinking purpose** 5. This is the end of report


CHEMIST
P.H.E. SUB DIVISION
LAKHNADON


ASSISTANT ENGINEER
P.H.E. SUB DIVISION
LAKHNADON

SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

It is Certified that an inspection team headed by the Authorized officer of Public Health Department Visited of the **KAVYA INTERNATIONAL SCHOOL, Village Sarasdol, Ghansor Road Lakhnadon** District Seoni (M.P.) on date 24/12/2020 and found that the school **KAVYA INTERNATIONAL SCHOOL, Village Sarasdol, Ghansor Road Lakhnadon** District Seoni (M.P.) has safe drinking water facilities for the student and member of staff of the Institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the state Government.

The above valid for a period of Three years from the Issue.

Signature: 

Seal:

Name:

Designation:

मुख्य स्वास्थ्य अधिकारी
नगरपालिका, परिषद, लखनादीन (म.प.)
20.1.2023

To,

Kavya International School,
Village Sarasdol, Ghansor Road,
Lakhnadon District Seoni (M.P.)


PRINCIPAL

Kavya International School
Sarasdol Lakhnadon (M. P.)


DIRECTOR
Kavya International School
Sarasdol Lakhnadon (M. P.)